

Evidence of Performance

Air permeability, Watertightness, Resistance to wind load



Expert Statement

No. 12-001016-PR01
(GAS-A01-02-en-01)

Client	Sistem Alüminyum San. ve Tic. A.Ş. Çakmaklı Mevki Akçaburgaz Mh 58.Sk. No:4 Kiraç Esenyurt - İstanbul Turkey
Product	Tilt and turn window with fixed sublight
Designation	AluTech W55-2mm Yalıtımlı Doğrama Sistem
Performance-relevant product details	Aluminium profiles with thermal break
Overall dimensions (WxH)	1,100 mm x 2,100 mm
Special features	-/-

Basis
EN 14351-1:2008+A1:2010

Test standard:
EN 1028:2000-08
EN 1027:2000-08
EN 12048-1:2003-11
EN 12211:2000-08
EN 14609:2004-08
Corresponds to the national standards (e. g. DIN EN)

Instruction for use

This expert statement serves to demonstrate the adjacent characteristics of windows.

This expert statement does not cover all the performance characteristics listed in the product standard.

Validity

The data and results refer solely to the tested and described specimen. Classification remains valid as long as the product and the above basis remain unchanged. The results can be extrapolated under the manufacturer's own liability subject to observance of the relevant specifications set out by the applicable product standard. This test/evaluation does not allow any statement to be made on any further characteristics regarding performance and quality of the construction presented, in particular the effects of weathering and ageing were not taken into account.

Notes on publication

The ift-Guidance Sheet "Advertising with ift test documents" applies. The cover sheet can be used as an abstract.

Contents

The expert statement contains a total of 4 pages.

- 1 Order
- 2 Basis
- 3 Assessment
- 4 Results and statement

Air permeability according to EN 12207:1999-11



Class 4

Watertightness according to EN 12208:1999-11



Class E900

Resistance to wind load according to EN 12210:1999-11/AC:2002-08



Class C3 / B3

ift Rosenheim
15.06.2012

Robert Kolačný, Dipl.-Ing. (FH)
Deputy Head of Testing Department
Building Components

Rolf Schnitzler, Dipl.-Ing. (FH)
Operating Product Officer
Building Components



TECHNICKÝ A ZKUŠEBNÍ ÚSTAV STAVEBNÍ PRAHA, s. p. (TECHNICAL
AND TESTING BUILDING INSTITUTE PRAGUE, state enterprise)
affiliate 0400 - Teplice, testing laboratory 1018.4 accredited by ČIA
Tolstého 447, 415 03 Teplice, tel.: 417 537 382, 417 537 414, fax: 417 537 414

Order No.: Z040 10 0202

REPORT

on measuring of sound-transmission loss according to ČSN EN ISO 140-3

No. 040-036976

Customer: SİSTEM ALÜMİNYUM SAN. ve TİC. A.Ş.,
Çakmaklı Mevkii Akçaburgaz Cad. 58.Sok. No:4 Kıraç Büyükçekmece
İSTANBUL/ TURKEY

No. of copies: 4

Copy No.:

Annexes: 1

Caution: *Without the written consent of TZÚS, the Report may not be reproduced otherwise than as a whole unit. The results apply to the mentioned subject of testing only.*

Teplice, 25.10.2010

Evidence of Performance

Resistance to wind load
Watertightness
Air permeability

Test report 102 43902/1e



Client **Sistem Alüminyum San. ve Tic.
A.S.**
Çakmaklı Mah. Akcaburgaz Cad. 58 Sk. No.4 Kirac

Esenyurt-Istanbul
Turkey

Basis
EN 14351-1 : 2008-03

Test standards:
EN 1026 : 2000-08
EN 1027 : 2000-08
EN 12211 : 2000-08
EN 12048-1 : 2003-11
EN 14609 : 2004-03

Corresponds to the national standard. (DIN EN)

Product	Tilt and turn window with fixed sublight
System	AluTech W55 1,6 Yalitimli Dograma Sistem
Overall dimensions (W x H)	1,100 mm x 2,100 mm
Frame material	Aluminium profiles with thermal break
Special features	-/-

Representation



Instruction for use

The present test report serves to demonstrate the above characteristics of windows according to EN 14351-1:2008-03. The results obtained can be used by the manufacturer as the basis for the manufacturer ITT test report summary. The conditions and requirements set out by EN 14351-1:2008-03 shall be observed.

Validity

The data and results refer solely to the tested and described specimen.

The test results can be extrapolated as per EN 14351-1, under observance of Annex E 1., under the manufacturer's own responsibility.

The test does not allow any statement to be made on further characteristics of the present structure and quality, in particular the effects of weathering and ageing.

Notes on publication

The ift-Guidance Sheet "Conditions and Guidance for the Use of ift Test Documents" applies.

The cover sheet can be used as an abstract.

Contents

The report contains a total of 14 pages.

Resistance to wind load – EN 12210



Class C3 / B3

Watertightness – EN 12208



Class E900

Air permeability – EN 12207



Class 4

ift Rosenheim
21. Juni 2010


Jörg Peter Lass, Dipl.-Ing. (FH)
Head of Testing Department
ift Centre Windows & Facades


Robert Kolacny, Dipl.-Ing. (FH)
Test engineer
ift Centre Windows & Facades



ift Rosenheim GmbH
Geschäftsführer:
Dipl.-Ing. (FH) Ulrich Sieberath
Dr. Jochen Reich

Theodor-Gierl-Str. 7 - 9
D-83026 Rosenheim
Tel.: +49 (0)8031/201-0
Fax: +49 (0)8031/281-290
www.ift-rosenheim.de

Sitz: 83026 Rosenheim
AG Traunstein, HRB 14763
Sparkasse Rosenheim
Kto. 3322
BLZ 711 500 00

Notified Body Nr.: 0757
Anerkennung PUZ-Stelle BAY 18

DIN EN ISO 9001
DIN EN ISO 14001
TGA-2010-09-00
TGA-2010-09-00